

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 11414  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35536

1. OWNER Santa Barbara palms LP ADDRESS AT WELL LOCATION 4880 Santa Barbara Street  
 MAILING ADDRESS 2655 S. Rainbow Blvd. #401 Las Vegas, NV 89146  
Las Vegas, NV 89146 Las Vegas, NV

2. LOCATION SE 1/4 SE 1/4 Sec 19 T 21 S R 62 E Clark County

PERMIT NO. \_\_\_\_\_ Parcel No. 161-19-803-001 Subdivision Name \_\_\_\_\_  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1-40' Dewater well				
Aluvium		0	3	3
Silt		3	12	9
Sandy Silt	x	12	14	2
Silty clay		14	32	18
Clay		32	40	8
Waiver# DW-1321				
WSG84				
N36 06. 100'				
W115 04. 990'				

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 0 Feet 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	37	1/4	0	40

Perforations:  
 Type perforation Machine  
 Size perforation 1/4"  
 From 20 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 0 feet to 40 feet

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ALLEN DRILLING INC.  
 (CONTRACTOR)

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

Address 4015 WEST TOMPKINS AVE.  
 (CONTRACTOR)  
LAS VEGAS, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2231-Victor Estes  
 Signed Victor Estes  
 By driller performing actual drilling on site or contractor  
 Date July 18, 2011

DCNR/DWR  
 RECEIVED  
 JUL 20 2011  
 LAS VEGAS OFFICE