

ORIGINAL

# AMENDED

WHITE—DIVISION OF WATER RESOURCES  
CANARY—CLIENT'S COPY  
PINK—WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 114158  
Permit No. \_\_\_\_\_  
Basin. 209

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

## WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35693

1. OWNER Guy Davis  
MAILING ADDRESS PO Box 394  
Alamo NV 89001  
2. LOCATION NW 1/4 SW 1/4 Sec. 22 T. 7  
PERMIT NO. 0 08-29-34  
Issued by Water Resources Parcel No. Subdivision Name

ADDRESS AT WELL LOCATION 1/4 mile west of mile marker # 35 US 93, Sharp Ranch Road  
N 61 E Lincoln County

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
This well had a breach in casing. 5" flush joint. Casing was installed to 55'.				
Packer Gaskets were installed at 55'-35' and 25'.				
No perforations in 5" liner				
GPS WGS 84 N 320 12.434 W 115° 08149				
<b>DCNR/DWR RECEIVED</b>				
SEP 06 2011				
<b>LAS VEGAS OFFICE</b>				

8. WELL CONSTRUCTION  
Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet  
HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	PVC	1.250	0	55

Perforations:  
Type perforation ⊘  
Size perforation ⊘  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal \_\_\_\_\_  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 14 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality good

Date started 6-4-2011 20  
Date completed 6-4-2011 20

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		4

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Davis Drilling and Pumps Contractor  
Address H.C. 61 Box 54 Contractor  
Hiko NV 89017  
Nevada contractor's license number issued by the State Contractor's Board 0028266  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191  
Signed Mike Davis  
By driller performing actual drilling on site or contractor  
Date 7-8-2011