

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **35462**

1. OWNER BAC HOME LOAN SERVICES
GREENSPAN BROKEAGE
 MAILING ADDRESS 2340 E CALVADA ST #6
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 1500 W CHINA ST

2. LOCATION NW 1/4 SE 1/4 Sec. 29 T 20
 PERMIT NO. _____
 Issued by Water Resources _____
 Parcel No. 40-253-20

NSR 53 E NYE County
UNIT 5 CALVADA VALLEY Subdivision Name

3. WORK PERFORMED
 New Well
 Deepen
 Replace
 Abandon
 Recondition
 Other _____

4. PROPOSED USE
 Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Test
 Stock

5. WELL TYPE
 Cable
 Air
 Rotary
 Other _____
 RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	8	8
CALICHIE		8	25	17
CLAY		25	60	35
CALICHIE		60	75	15
CLAY		75	90	15
CALICHIE	WB	90	110	20
CLAY		110	135	25
CALICHIE	WB	135	155	20
CLAY		155	170	15
CALICHIE	WB	170	195	25
CLAY		195	200	5

N36°10'51.6"
 W116°02'26.9"

DCNR/DWR
 RECEIVED

JUL 20 2011

LAS VEGAS OFFICE

Date started 7/14/2011, 19
 Date completed 7/14/2011, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet
200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.280	0	200

Perforations:
 Type perforation SCREEN
 Size perforation .032
 From 140 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 82 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
 Contractor

Address 1220 MANSE RD
 Contractor

PAHRUMP, NV. 89048

Nevada contractor's license number issued by the State Contractor's Board 47333

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426

Signed [Signature]
 By driller performing actual drilling on-site or contractor

Date 7/18/2011