

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 114172
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **35471**

1. OWNER **ROBERT L DABNER** ADDRESS AT WELL LOCATION **580 W HURACAN ST**
 MAILING ADDRESS **8636 S PHILLIPS AVE**
CHICAGO, IL 60617
 2. LOCATION **SW 1/4 SE 1/4 Sec. 28 T 20 N53R 53 E NYE** County
 PERMIT NO. **40-402-23** **UNIT 5 CALVADA VALLEY**
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING 8" WELL		0	140	140
CLAY		140	145	5
CALCHIE	WB	145	165	20
CLAY		165	175	10
CALICHIE	WB	175	190	15
CLAY		190	200	10
N36°10'38.8"				
W116°01'25.6"				

8. WELL CONSTRUCTION
 Depth Drilled 0 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)

EXISTING	Inches	From	To	Feet	Feet
		0	140		
8	Inches	140	200	Feet	Feet
	Inches			Feet	Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94.188	.188	0	140
4.5	2.37	.248	140	200

Perforations:
 Type perforation **SCREEN**
 Size perforation **.032**
 From 140 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal **EXISTING**
 Placement Method: Pumped Poured
 Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Gravel Packed: Yes No
 From 140 feet to 200 feet

9. WATER LEVEL
 Static water level 88 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor
 Address **1220 MANSE RD** Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**
 Signed  By driller performing actual drilling on-site or contractor
 Date **7/18/2011**

Date started 5/13/2011, 19
 Date completed 5/13/2011, 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.		

**DCNR/DWR
 RECEIVED
 JUL 20 2011**