STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114183
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35977

1. OWNER U.S.A.
MAILING ADDRESS 13825 Hinson Street
Sloan, Nv. 89054

ADDRESS AT WELL LOCATION 13825 Hinson Street
Sloan, Nv.
Subdivision Name:
County: Clark

2. LOCATION NW¼ NE ¼ Sec 19 T 23 N OR 61 E
PERMIT/WAIVER No. 80725T (Issued by Water Resources) | 191 19 501 001 (Parcel No.)
Latitude 35° 56.306 N
Longitude 115° 11.682 W
UTM E N
☑ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. CONSTRUCTION PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, clay, cobble				
Conglomerate		0	180	180
Grey volcanics		240	180	420
Red quartzite		260	420	680
Grey Limestone	X	220	680	900
25 GPM @ 680'				
110 GPM @ 760'				

DCNR/DWR RECEIVED
JUL 20 2011
LAS VEGAS OFFICE

Date started: June 6, 20 11
Date completed: June 10, 20 11

9. WELL CONSTRUCTION
Depth Drilled 900 Feet Depth Cased 898 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
18	Inches	0	Feet	30	Feet
12	Inches	30	Feet	900	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	42	.250	0	30
48	22.6	.250	+2	898

Perforations:
Type of perforation Factory milled
Size of perforation 1/8"
From 498 feet to 898 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☑ Yes ☐ No
☐ Neat Cement 0 to 215 ☐ Pumped ☑ Poured
☑ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☑ Yes ☐ No 215 to 900 ☐ Pumped ☑ Poured
Type: 3/8" washed rock
Bentonite Chips: ☐ Yes ☑ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 512.8 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 70 °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
91	31'	24 hr

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Webber Drilling (Contractor)
Address PO Box 40 Overton, Nv. 89040 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0025887
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238
Signed Bryan Anzalone (By driller performing actual drilling on-site or contractor)
Date July 18, 2011

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY