STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114353
Permit No.
Basin 137 B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65795

1. OWNER Round Mountain Gold Corp DV-11-12
MAILING ADDRESS PO Box 480
Round Mountain, NV 89045

ADDRESS AT WELL LOCATION Round Mountain Mine
Round Mountain, NV
Subdivision Name: County: Nye

2. LOCATION NW¼SW¼ Sec19T10N/ R44E
PERMIT/WAIVER NO. M/O 1666 (Issued by Water Resources) Parcel. No.

Latitude
Longitude
UTM E 492385 ☒ NAD 27
N 4284426 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
White/gray		0	140	140
Clay		140	160	20
White rock		160	240	80
Clay		240	290	50
White/black rock		290	400	110

Date started: July 29, 20 11
Date completed: July 30, 20 11

RECEIVED 2011 AUG 18 PM 1:30 STATE ENGINEER'S OFFICE

9. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9.875 Inches	0 Feet	10 Feet
6.5 Inches	10 Feet	400 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	.98	.218	+3	400

Perforations:
Type of perforation Slotted
Size of perforation .25
From 50 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 10 to 40 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 45 to 400 ☒ Pumped ☐ Poured
Type: 1/4 x 3/8
Bentonite Chips: ☒ Yes ☐ No 40 to 45 ☐ Pumped ☒ Poured
Type: 3/4 hole plug

7. Water Level
Static water level: N/A feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave. (CONTRACTOR)
SLC, UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2085-T1
Signed
By driller performing actual drilling on site or contractor
Date August 12, 2011

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY Forms Provided by Forms-On-A-Disk • (214) 340-9429 • FormsOnADisk.com

38.710306°N 117.087583°W NAD27