STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114416
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36118

1. OWNER Safeway Super Service Centers%J Carson
MAILING ADDRESS 2424 S Highland
Las Vegas NV 89102

ADDRESS AT WELL LOCATION Mavrick Truck Stop
EW-1 3225 N Las Vegas Blvd
Las Vegas NV 89115

2. LOCATION NW ¼ NW ¼ Sec 18 T 20S N/S R 62 E
PERMIT/WAIVER No. R-1525 (Issued by Water Resources) 140-18-101-005 Parcel No.

Latitude 36 13 01.00
Longitude 115 05 43.00
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: County:

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other... auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	3"	3
lt brn silty sand w/clay		3"	20	17
silt w/gravel		20	40	20
brn silty clay w/gravel		40	55	15
gray silty clay		55	65	10
tan silty clay		65	75	10

DCNR/DWR RECEIVED SEP 21 2011 LAS VEGAS OFFICE

Date started 31-Aug , 20 11
Date completed 31-Aug , 20 11

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
n/a			

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	75	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.5	3.54	.250	0	35
6.5	S/S	S/S	35	75

Perforations:
Type of perforation wire wrapped
Size of perforation 0.040
From 35 feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 25
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 35 feet to 75 feet

9. WATER LEVEL
Static water level 42 feet below land surface
Artesian flow n/a G.P.M n/a P.S.I
Water temperature n/a °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name W.D.C. Exploration & Wells (Contractor)
Address 739 W Sunset (Contractor)
Henderson NV 89011
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2371
Signed (By driller performing actual drilling on site or contractor)
Date 9-20-11

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY

3700