

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 114419
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35956

1 OWNER CITY OF LAS VEGAS
MAILING ADDRESS 400 STEWART AVE.
LAS VEGAS NV.

ADDRESS AT WELL LOCATION PUBLIC RIGHT OF WAY
Subdivision Name: _____ County: CLARK

2 LOCATION SE 1/4 SR 06 T 21 N SR 61 E
PERMIT/WAIVER No. 16206899 007
Issued by Water Resources Parcel No. _____

Latitude 36° 08 44.2 UTM E _____ NAD 27
Longitude 115° 11 27.1 N _____ NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? no
If yes, what is replacement well NOI? _____

Is there an existing well log? no
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
<u>31</u>		<u>31</u>	

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>3/8 40</u>		<u>31</u>

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: UNACCESSIBLE PIPE + SCREEN BROKE UP + GROUTED
Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations: NONE

Existing Perforations:

Type of perforation	Size of perforation	From	feet to	feet
<u>MACHINE SLOT</u>	<u>020</u>	<u>29</u>		<u>31</u>

Type of perforator used: NONE

From	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL
Static water level 19 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<u>0</u>	<u>31</u>	<u>feet</u>	<u>CEMENT GROUT</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments
SVB

DCNR/DWR RECEIVED
AUG 22 2011

LAS VEGAS OFFICE

Neat Cement Fluid Weight 94 lbs/gal 5.2
Bentonite Grout _____ % bentonite
Date Started 8-15-2011
Date Completed 8-15-2011

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING Contractor
Address 7150 PLACID ST LAS VEGAS NV 89119 Contractor
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed M. D. W. Victor
By driller performing actual drilling on-site or contractor
Date 8-15-2011