WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 114448
Permit No.
Basin 137 B

NOTICE OF INTENT NO. 63569

1. OWNER Gene Schwarz
MAILING ADDRESS P.O. Box 1317 Round Mtn Nevada 89045
ADDRESS AT WELL LOCATION West Crowell Field Road Carvers NV

2. LOCATION SW ¼ NE ¼ Sec. 29 T. 11 N/S R. 43 E. NYE County
PERMIT NO. 0 Issued by Water Resources
010-371-06 Parcel No.
0 Subdivision Name CARVER'S AREA

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	11	11
Sand - Boulders		11	26	15
Clay		26	40	14
Sand - Boulders		40	48	8
Hard Rock		48	60	12
Sand - Boulders	X	60	85	25
Clay - gravel	X	85	120	35
Hard Rock		120	125	5

GPS WGS 84
N 38° 47.263
W 117° 10.210

2011 SEP 26 AM 11:26
STATE ENGINEER'S OFFICE

Date started 8-26-2011, 20
Date completed 8-27-2011, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		2

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	125 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 1/2	PVC	Sch 40	0	125

Perforations:
Type perforation Sqw cut
Size perforation 1/8" x 3"
From 65 feet to 125 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 125 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps Contractor
Address HC 61 Box 54 Hiko NV 89017 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0028866
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed 8-29-2011 By driller performing actual drilling on site or contractor
Date Mike Davis

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

38.787,792°N NAD 27
-117.169,094°W
TR