

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 114485
 Permit No. _____
 Basin 212
 NOTICE OF INTENT NO. 35999

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER COUNTY OF CLARK
 MAILING ADDRESS 500 S. Grand Central Pkwy
LAS VEGAS, NV 89155
 ADDRESS AT WELL LOCATION Wetland Park Nature Center
7050 Wetland Park Lane
Las Vegas, NV
 2. LOCATION NE $\frac{1}{4}$ NW $\frac{1}{4}$ Sec 26 T 21 S R 62 E CLARK County
 PERMIT NO. DW1305 161-26-101-008
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Plug 1-Dewatering wells				
Pulled pump & casing				
Trimmie 1.5 yards of				
9 sack cement grout into well to surface.				
WGS84				
N36 05. 978'				
W115 01. 338'				

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet
 HOLE DIAMETER (BIT SIZE)
 From 24 Inches To 0 Feet 40 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14</u>	<u>36.71</u>	<u>0.250</u>	<u>0</u>	<u>40</u>

Perforations:
 Type perforation Machine
 Size perforation 1/4"x2.5"x21 per ft.
 From 20 feet to 40 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal _____ Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 0 feet to 40 feet


9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 7/29, 20 11
 Date completed 8/1, 20 11

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Draw Down		
	G.P.M.	(Feet Below Static)	Time (Hours)

Name ALLEN DRILLING INC.
(CONTRACTOR)
 Address 4015 WEST TOMPKINS AVE.
(CONTRACTOR)
LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917
 Nevada driller's license number issued by the ABDS2161-David
 Division of Water Resources, the on-site driller Strouse
 Signed 
 By driller performing actual drilling on site or contractor
 Date August 11, 2011

DCNR/DWR
 RECEIVED
 AUG 15 2011
 LAS VEGAS OFFICE