

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 114612
 Permit No. 80471
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35475

1. OWNER GASSER NESTMAN PROPERTIES, LLC ADDRESS AT WELL LOCATION 3971 S HOMESTEAD RD
 MAILING ADDRESS 74 E 500 SOUTH #300
BOUNTIFUL, UT 84010

2. LOCATION SW 1/4 SW 1/4 Sec. 31 T 20 N/S R 54 E NYE County
 PERMIT NO. 80471 Issued by Water Resources Parcel No. 41-231-15 Subdivision Name UNIT 1 CALVADA VALLEY

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. CDMM PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SILT		0	10	10
CLAY		10	25	15
CALICHIE		25	50	25
CLAY		50	80	30
CALICHIE	WB	80	95	15
CLAY		95	115	20
CALICHIE	WB	115	120	5
CLAY		120	140	20
CALICHIE	WB	140	165	25
CLAY		165	175	10
CALICHIE	WB	175	200	25

COMMERCIAL WELL

N36°09'43.1"
 W115°57'30.1"

DCNR/DWR
 RECEIVED

DEC 01 2011

LAS VEGAS OFFICE

Date started 9/21/2011, 19
 Date completed 9/21/2011, 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 200 Feet
12 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.280	0	200

Perforations:
 Type perforation SCREEN
 Size perforation .032
 From 140 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 605 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address 1220 MANSE RD Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 9/22/2011