M-2170

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 114622
Permit No. 75783
Basin 087

NOTICE OF INTENT NO. 60897 i

1. OWNER Randy & Kami Solile
MAILING ADDRESS 13390 Welcome Way Reno, NV 89511
ADDRESS AT WELL LOCATION 13410 Welcome Way Reno NV 89511

2. LOCATION NW ~~SE~~ NE ~~SE~~ ¼ Sec. 24 T. 18 N/S R. 19 E. Washoe County
PERMIT NO. WL070152 75783/W-607 Issued by Water Resources
Parcel No. 049-165-03
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel some Cables brown		0	245	
Clayey gravel w/sand brown		245	295	
Sand Stone Brown		295	315	
Sand stone-med Coarse Brown		315	330	
med-coarse Brown		330	355	
Sand stone silty fine Sand Brn		355	370	
Fine silty Sand stone Brown		370	450	
Sand stone Med grained Brn		450	485	
Fine silty Sand Brw		485	505	
Fine clayey Sand Stone Brn		505	525	
Fine Silty Sand Stone Brn		525	630	
Sand stone fine to Med Brown		630	655	
clayed gravel & Sand Med Coarse		655	690	
Sand gravel & Cobbles Brown		690	705	
Silt Brown		705	715	
N 39.417259				
W 119.796118 NAD27				
GPS Coords:				
N 39.41717				
W 119.79714				
datum: NAD 83				

Date started 12/21 2007
Date completed 2/15 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
291	18	60

2008 SEP -2 PM 1:09

8. WELL CONSTRUCTION
Depth Drilled 715 Feet Depth Cased 697 Feet

HOLE DIAMETER (BIT SIZE)
10 Inches From 0 Feet To 715 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 11	3733	.188	0	317

Perforations:
Type perforation
Size perforation 032
From 317 feet to 697 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 100 feet to 715 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow 291 G.P.M. P.S.I.
Water temperature 20 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Western Strata Exploration Contractor
Address PO Box 657 Clarksburg Ca 95612 Contractor
Nevada contractor's license number issued by the State Contractor's Board C230034236A
Nevada driller's license number issued by the Division of Water Resources, the on site driller M-1978
Signed [signature] By driller performing actual drilling on site or contractor
Date 2/25/08

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(D)-627