STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114630
Permit No.
Basin Ø90

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67641

1. OWNER ARAMARK- Lake Tahoe
MAILING ADDRESS P.O. Box 12309
Zephyr Cove NV 89448

ADDRESS AT WELL LOCATION 760 Hwy 50
Zephyr Cove Nevada 89448
Subdivision Name: N/A County: Douglas

2. LOCATION SE ¼ NW ¼ Sec 10 T 13 N/S R 18 E
PERMIT/WAIVER No. 2-00012 1318-10-000-002
NDEP# Issued by Water Resources Parcel No.

Latitude N39.00622° UTM E ☐ NAD 27
Longitude W119.94795° N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SV EW-02				
red-brown clay w/sand		5	10	5
red-brown silty sand moist		10	15	5
red-brown silty sand w/gravel sat	16.8	15	20	5

Plugged by Well log 126726

RECEIVED 2011 SEP 14 AM 11:47 STATE ENGINEER'S OFFICE

Date started: 9/8, 20 11
Date completed: 9/8, 20 11

9. WELL CONSTRUCTION
Depth Drilled 19 Feet Depth Cased 19 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.25	Inches	0	Feet	19	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		sch 40	19	1/2

Perforations:
Type of perforation slotted screen
Size of perforation 0.020
From 19 feet to 5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 2.5 to 0 ☐ Pumped ☒ Poured
☐ ≥80% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 19 to 4.5 ☐ Pumped ☒ Poured
Type: Cemex Sand #3 lapis lustre
Bentonite Chips: ☒ Yes ☐ No 4.5 to 2.5 ☐ Pumped ☒ Poured
Type: Pure Gold Medium Chips

7. Water Level
Static water level: 16.8 feet below land surface
Artesian Flow: no G.P.M. P.S.I.
Water Temperature: cold °F
Quality: Murky

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Dale Lehman
Contractor
Address 520 Edison Way
Contractor
Reno NV 89502
Nevada contractor's license number issued by the State Contractor's Board 0062596 RSI Drilling
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1976
Signed Dale Lehman
By driller performing actual drilling on site or contractor
Date 9/12/11

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-08)

39.006312°N NAD27
119.946936°W Dec/Deg