STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114634
Permit No.
Basin 090

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 67641

1. OWNER ARAMARK - Lake Tahoe
MAILING ADDRESS P.O. Box 12309
Zephyr Cove NV 89448

ADDRESS AT WELL LOCATION 760 Hwy 50
Zephyr Cove Nevada 89448
Subdivision Name: N/A
County: Douglas

2. LOCATION SE ¼ NW ¼ Sec 10 T 13 N/S R 18 E
PERMIT/WAIVER No. 2-00012 1318-10-000-002
NDEP# Issued by Water Resources
Parcel No.

Latitude N 39.00722°
Longitude W 119.948430°
UTM E
N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ZC MW7 | | | | |
| red-brown silty sand dry | | 0 | 2 | 2 |
| black silty clay moist | | 2 | 3 | 1 |
| red-brown poor sand | 3.75 | 3 | 5 | 2 |
| grey poor sand | | 5 | 25 | 20 |

RECEIVED 2011 SEP 14 AM 11:48 STATE ENGINEER

Date started: 9/9, 20 11
Date completed: 9/9, 20 11

7. Water Level
Static water level: 3.75 feet below land surface
Artesian Flow: No G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Murky

8. N/A WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

9. WELL CONSTRUCTION
Depth Drilled 24 Feet Depth Cased ~~24~~ 23 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10.75 Inches | | 0 Feet | 24 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4 | | sch 40 | 23 | -3 |
| | | | | |

Perforations:
Type of perforation slotted screen
Size of perforation 0.010
From 23 feet to 3 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 1.5 to 0.5 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0.5 to 0 ☐ Pumped ☒ Poured
☐ ≥80% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 23 to 2.5 ☐ Pumped ☒ Poured
Type: Cemex Sand 2/12 Lapis lustre
Bentonite Chips: ☒ Yes ☐ No 2.5 to 1.5 ☐ Pumped ☒ Poured
Type: Pure Gold Medium Chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) DALE LEHMAN
Address (Contractor) 520 Edison WAY
Reno NV 89502
Nevada contractor's license number issued by the *State Contractor's Board* 0062596 RSI Drilling
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-1976
Signed Dale Lehman
(By driller performing actual drilling on site or contractor)
Date 9/12/11

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

39.007312 °N
119.947416 °W
NAD27
Dec/Deg