

Amended

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 11464b
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35050

1. OWNER CalNev Pipe Line, LLC
MAILING ADDRESS 1100 Town & Country Rd
Orange, CA 92869

ADDRESS AT WELL LOCATION NWC Hacienda & Valley View
Las Vegas, NV 89119
Subdivision Name: County: Clark

2. LOCATION SE 1/4 NE 1/4 Sec 30 T21 N3R 61 E
PERMIT/WAIVER No. 162-30-601-012
Issued by Water Resources Parcel No.

Latitude 36.09377948 N UTM E NAD 27
Longitude -115.1901109 W N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
cliche		0	15	
Sand Gravel CL		15	32	
cliche		32	40	
Silty sand		40	45	
cliche		45	50	
CL		50	56	
CL Gravel		56	60	
cliche		60	66	
Silty CL		66	112	
Silty sand		112	118	

WELL CONSTRUCTION				
Depth Drilled	Feet	Depth Cased	Feet	
118		115		
HOLE DIAMETER (BIT SIZE)				
From	To	From	To	
8		8	118	

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2 lbs	Sch 40	0	95

Perforations:
Type of perforation Factory slotted
Size of perforation .020
From 95 feet to 115 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: Yes No
 Neat Cement 1 to 90 Pumped Poured
 Cement Grout to Pumped Poured
 Concrete Grout to Pumped Poured
 ≥30% Bentonite Grout to Pumped Poured

Gravel Pack: Yes No 93 to 118 Pumped Poured
Type: #3 Rmc
Bentonite Chips: Yes No 90 to 93 Pumped Poured
Type: medium WYO-Ben

Date started: 9-26-11
Date completed: 9-30-11

7. Water Level
Static water level: 65 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Contractor
Address 1333 W. 9th St Contractor
Upland, CA 91746
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2434
Signed [Signature] BLY contractor
By driller performing actual drilling on site or contractor
Date 10-24-11 Revised 12-22-11

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
Bail & Pump	0.75		7
DCNR/DWR RECEIVED			
FEB 23 2012			

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

LAS VEGAS OFFICE



**BOART
LONGYEAR**

C57 #694686

Boart Longyear E. I. Division

1333 W. 9th St

Upland Calif. 91786

Tel: 909-946-1605 • Fax: 909-946-1608

www.boartlongyear.com

To whom it may concern

Attn: Steven Martinez

Please replace previous submitted Well Reports with the revised ones attached as the owner information was incorrect.

Let me know if any questions

Thanks,

Mario Romero

909-946-1640

**DCNR/DWR
RECEIVED**

FEB 23 2012

LAS VEGAS OFFICE