

Amended

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114648
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35052

1. OWNER Cal Nev Pipe Line, LLC
MAILING ADDRESS 1100 Town & Country Rd
Orange, CA 92668

ADDRESS AT WELL LOCATION 5295 Procyon St.
Las Vegas, NV 89119
Subdivision Name
County: Clark

2. LOCATION SW 1/4 NW 1/4 Sec 29 T 21 NBR 61 E
PERMIT/WAIVER No. 1162-29-203-005
Issued by Water Resources Parcel No.

Latitude 36.09377497 N UTME NAD 27
Longitude 115.187974 W N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test Monitor
 Municipal/Industrial Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
cliche		8	11	
CL		11	21	
Sandy silt		21	25	
CL		25	31	
Sandy Gravel		31	36	
cliche		36	40	
CL Gravel		40	44	
cliche		44	51	
Silty CL		51	62	
cliche		62	66.5	
Clay silt		66.5	69	
Clay Gravel		69	71	

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
70		70	

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
8	70		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2 lbs	5/8	0	25

Perforations:
Type of perforation Factory slotted
Size of perforation
From 25 feet to 70 feet

Annular Seal: Yes No
 Neat Cement 1 to 20 Pumped Poured
 Cement Grout to Pumped Poured
 Concrete Grout to Pumped Poured
 ≥30% Bentonite Grout to Pumped Poured
Gravel Pack: Yes No 23 to 70 Pumped Poured
Type: #3 RMC sand
Bentonite Chips: Yes No 20 to 23 Pumped Poured
Type: medium chips WYO-Ben

Date started: 10-1 20 11
Date completed: 10-3 20 11

7. Water Level
Static water level: 41 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality:

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bail <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
Bail		Run dry	1.5

DCNR/DWR RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Contractor
Address 1333 W. 9th St Upland, CA 91786 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2439
Signed [Signature] BLK Contractor
By driller performing actual drilling on site or contractor
Date 10-24-11 Revised 12-22-11

LAS VEGAS OFFICE



**BOART
LONGYEAR**

C57 #694686

Boart Longyear E. I. Division

1333 W. 9th St

Upland Calif. 91786

Tel: 909-946-1605 • Fax: 909-946-1608

www.boartlongyear.com

To whom it may concern

Attn: Steven Martinez

Please replace previous submitted Well Reports with the revised ones attached as the owner information was incorrect.

Let me know if any questions

Thanks,

Mario Romero

909-946-1640

**DCNR/DWR
RECEIVED**

FEB 23 2012

LAS VEGAS OFFICE