STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114726
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36083

1. OWNER Leonard Shapiro CK 3285 S. Nellis Blvd. LLC
MAILING ADDRESS 3335 Turtle Head Peak Drive
Las Vegas, NV 89135

ADDRESS AT WELL LOCATION 3285 S. Nellis Blvd.
Las Vegas, NV 89121
Subdivision Name: MW-4 County: Clark

2. LOCATION SE ¼ SE ¼ Sec 8 T 21S N/S R 62 E
PERMIT/WAIVER No. 16108810062
Issued by Water Resources Parcel No.

Latitude 36*07'47.53N
Longitude 115*03'55.97W
UTM E N
[x] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC [ ] Air [x] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand w/ Gravel		0	8	8
Cemented		8	9	1
Clay		9	15	6
Silty Sand	16	15	20	5
Clay		20	28	8

DCNR/DWR
RECEIVED
JAN 24 2012
LAS VEGAS OFFICE

Date started: 18-Jan , 20 12
Date completed: 18-Jan , 20 12

9. WELL CONSTRUCTION
Depth Drilled 28 Feet Depth Cased 27 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	28	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		SCH 40 PVC	0	7

Perforations:
Type of perforation Factory Slotted
Size of perforation .020
From 7 feet to 27 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[x] ≥30% Bentonite Grout 1 to 3 [ ] Pumped [x] Poured
Gravel Pack: [x] Yes [ ] No 5 to 27 [ ] Pumped [x] Poured
Type: 8/12
Bentonite Chips: [x] Yes [ ] No 3 to 5 [ ] Pumped [x] Poured
Type: Medium 3/8

7. Water Level
Static water level: 16 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 739 W. Sunset Rd.
Contractor
Henderson, NV 89011
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2057
Signed
By driller performing actual drilling on site or contractor
Date 1/23/2012

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY