STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114738
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35829

1. OWNER 3F International Invertments LLC
MAILING ADDRESS 2710 Losee Rd
N. Las Vegas, NV 89030

ADDRESS AT WELL LOCATION 1550 N. Rancho Dr.
MW-13 Las Vegas, NV 89106
Subdivision Name: County: Clark

2. LOCATION NW ¼ NW ¼ Sec 29 T 20S N/S R 61 E
PERMIT/WAIVER No. 139-29-112-120
Issued by Water Resources Parcel No.

Latitude 36 11'16.95"
Longitude 115 11'7.57"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	3	3
Sandy Silt		3	9	6
Caliche		9	16	7
Sandy Clay		16	18	2
Caliche		18	23	5
Sandy Clay		23	30	7

DCNR/DWR
RECEIVED
JAN 12 2012
LAS VEGAS OFFICE

Date started: 13-Dec , 20 11
Date completed: 13-Dec , 20 11

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		SCH 40	0	30

Perforations:
Type of perforation Factory Slotted
Size of perforation .020
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 8 to 30 ☐ Pumped ☒ Poured
Type: SRI Supreme #8
Bentonite Chips: ☒ Yes ☐ No 1 to 8 ☐ Pumped ☒ Poured
Type: 3/8 medium Bentonite

7. Water Level
Static water level: 27 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells (Contractor)
Address 739 W. Sunset Rd (Contractor)
Henderson, NV 89011
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2381
Signed (By driller performing actual drilling on site or contractor)
Date 1-3-12

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY