STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114760
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK e DSB

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36051

1. OWNER Dowey Strip Holding LLC
MAILING ADDRESS 2390 E. Camelback Rd, Suite 210
Pheonix, AZ 85016

ADDRESS AT WELL LOCATION 4207 S. Las Vegas Blvd
Las Vegas, NV
Subdivision Name: County: Clark

2. LOCATION SW ¼ SW ¼ Sec 28 T 21S N/S R 61 E
PERMIT/WAIVER No. 162-28-401-001
Issued by Water Resources Parcel No.

Latitude 36 05 22.10
Longitude 115 10 20.07
UTM E N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other H.S.A.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
asphalt		0	3"	3"
Compacted Road Base		3"	1'	9"
Silty Sand Grey		1'	4'	3'
Caliche-Partialy cemented		4'	5.5'	1.5'
Sandy Silt - few pebbles-grey		5.5'	9'	3.5'
Caliche-Partialy cemented		9'	9.5'	.5'
Sandy Silt pale brown		9.5'	14'	4.5'
Clay partlialy cemented grey		14'	23'	9'
Caliche-Partialy cemented		23'	26'	3'
Sandy Silt trace of clay, gravels brown		26'	35	9'

DCNR/DWR
RECEIVED
NOV 16 2011
LAS VEGAS OFFICE

Date started: 7-Nov , 20 11
Date completed: 11/7/2011 , 20 11

9. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.25	Inches	0	Feet	35	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.500	2.01	0.237	.05	20

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.020
From 20 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 1 to 16 ☒ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 18 to 35 ☐ Pumped ☒ Poured
Type: #08
Bentonite Chips: ☒ Yes ☐ No 16 to 18 ☐ Pumped ☒ Poured
Type: 1/4" Medium / Bentonite Chips

7. Water Level
Static water level: 31 feet below land surface
Artesian Flow: na G.P.M. na P.S.I.
Water Temperature: na °F
Quality: good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
na		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 739 W Sunset Rd, Henderson NV 89011
Contractor
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2057-T1
Signed Bob
By driller performing actual drilling on site or contractor
Date 11/15/2011

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY