WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 114922
Permit No.
Basin 230

NOTICE OF INTENT NO. 36200

1. OWNER MIGUEL & LORENA SANCHEZ
MAILING ADDRESS PO BOX 267
AMARGOSA VALLEY, NV 89020

ADDRESS AT WELL LOCATION 1458 E NAVAJO WY

2. LOCATION SE 1/4 SE 1/4 Sec. 22 T 16 N/S R 49 E NYE County
PERMIT NO. (Issued by Water Resources) 19-541-19 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING 6" STEEL		0		
WELL			170	170
SAND & GRAVEL	WB	170	180	10
SANDY CLAY		180	185	5
SAND & GRAVEL	WB	185	200	15
N36°32'29.324"				
W116°26'10.704"				
EXSITING 6" STEEL WELL				
CONCRETE EXISTING				

DCNR/DWR
RECEIVED
FEB 28 2012
LAS VEGAS OFFICE

Date started 2/22/2012 , 19__
Date completed 2/22/2012 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 195 Feet Depth Cased 195 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING	Inches	0	Feet	170	Feet
5-3/4	Inches	170	Feet	200	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	10.78	.188	0	170
4	2.06	.237	0	195

Perforations:
Type perforation SCREEN
Size perforation .020
From 150 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal EXISTING
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 138 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 MANSE RD (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 2/23/2012

USE ADDITIONAL SHEETS IF NECESSARY