WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 115058
Permit No. 55257
Basin 207

NOTICE OF INTENT NO. 63568

1. OWNER Whipple Ranch
MAILING ADDRESS 1140 North main street Lund NV
ADDRESS AT WELL LOCATION 7 miles south of Lund ½ mile west of mile marker 450 SR 318

2. LOCATION NW ¼ NE ¼ Sec. 5 T. 10 N/S R. 62 E White Pine County
PERMIT NO. 55257 Issued by Water Resources | 11-380-05 Parcel No. | — Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| This well had a breech in casing and filled up to 125' with boulders and gravel | | | | |
| Well was cleaned to 158' and 14" casing was set inside the Existing 16" casing there is a 3/8" screen welded inside of 14" casing at 156'. I believe problem in well was at about 100' and possibly gravel was washing in from bottom this is the reason for screen | | | | |
| Well seem to be working fine at approx 1,000 gpm | | | | |
| GPS W65 84 11380 45.766 W 115°, 01.729 | | | | |
| * reconditioning original log 75727 | | | | |

Date started 7-1-2011, 20
Date completed 7-7-2011, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |
| | | |
| | | |
| | | |
| | | |
| | 38.762822°N NAD27 | |
| | 115.027969°W | |

8. WELL CONSTRUCTION
Depth Drilled 158 Feet Depth Cased 158 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | | .250 | 0 | 158 |
| | | | | |
| | | | | |

Perforations:
Type perforation factory
Size perforation 3/8" x 3"
From 58 feet to 158 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 9 feet below land surface
Artesian flow — G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps Contractor
Address HC61 Box 54 Hiko NV 89017 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis
By driller performing actual drilling on site or contractor
Date 7-8-2011

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627