DESI SW IS CORRECT SEE PERMIT NOT SURE WHO MADE CHANGE OWNERS LOG HAS SW

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115066
Permit No. 73563
Basin 137B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67703

1. OWNER Robert Beck SW
MAILING ADDRESS HC 60 Box 44501
NW Round Mountain, NV 89045

ADDRESS AT WELL LOCATION Big Smokey Valley
Round Mountain, NV 89045
Subdivision Name: County: Nye

2. LOCATION SW ¼ NW ¼ Sec 19 T 12N N/S R 44 E
PERMIT/WAIVER No. 73563 (Issued by Water Resources) Parcel No.

Latitude 38.88904 N
Longitude -117.08984 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	110	110
Brown Clay		110	114	4
Sand & Gravel	XX	114	300	186

Date started: 24-Jan, 20 12
Date completed: 3-Feb, 20 12

RECEIVED 2012 MAR -5 AM 11:30 STATE ENGINEER'S OFFICE

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
36	Inches	0	Feet	50	Feet
24	Inches	50	Feet	300	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30	39.5	.109	0	50
16	42.09	.250	0	300

Perforations:
Type of perforation Mill Cut
Size of perforation 3/16"
From 120 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 0 to 300 ☐ Pumped ☒ Poured
Type: 3/8" Well gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 50 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pump	2000	45'	9

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2307
Signed Wayne Young (By driller performing actual drilling on site or contractor)
Date 2/15/2012

(Rev. 03-08)

USE ADDITIONAL SHEETS IF NECESSARY

38.889110 °N
117.088921 °W
NAD27