

* Replaces original well log # 5317
 original well was converted
 to a stock well - see
 Waiver P-1201

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 115067
 Permit No. 18879
 Basin 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66672

1. OWNER FRED FULSTONE (F.I.M. Corp.) ADDRESS AT WELL LOCATION SOUTH SIDE OF SARONI LANE
 MAILING ADDRESS PO BOX 12 EAST WELL
SMITH VALLEY, NV 89430 Subdivision Name: _____ County: Lyon

2. LOCATION NE 1/4 NW 1/4 Sec 9 T 10N N/S/R 24 E Latitude 38° 44.836 N UTM E NAD 27
 PERMIT/WAIVER No. 18879 / Waiver P-1201 Longitude 119° 18.414 W N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SILTY CLAY		0'	18'	18'
SAND AND GRAVEL		18'	30'	12'
CLAY AND SAND		30'	66'	36'
BOULDERS, SAND & GRAVEL		66'	90'	24'
CLAY		90'	115'	25'
GRAVEL		115'	118'	3'
COBBLES AND BOULDERS		118'	128'	10'
SAND AND CLAY		128'	160'	32'
CLAY		160'	168'	8'
CLAY & VOLCANIC SANDS		168'	190'	22'
COBBLES		190'	228'	38'
CLAY		228'	236'	8'
SAND, GRAVEL & COBBLES		236'	240'	4'
CLAY		240'	255'	15'
SAND AND GRAVEL		255'	280'	25'
FRACTURED GRANITE		280'	335'	55'
CLAY AND GRAVELS		335'	370'	35'
GRAVEL		370'	378'	8'
CLAY AND SOME GRAVEL		378'	410'	32'
GRAVEL		410'	438'	28'
SAND AND GRAVEL		438'	452'	14'
SAND AND CLAY		452'	462'	10'
SAND, GRAVEL AND CLAY		462'	608'	146'

9. WELL CONSTRUCTION

Depth Drilled 608' Feet Depth Cased 600' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
36"	0'	30'
24"	30'	608'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30"		.250"	0'	30'
16"		.250"	30'	608'
3"		SCH. 40	+2'	118'

Perforations:

Type of perforation _____ MILL SLOT
 Size of perforation 0.090"

From	To
120' D.R.	240'
240' T.R.	320'
320' D.R.	400'
400' T.R.	440'
440' D.R.	600'

Annular Seal: Yes No

Neat Cement 0' to 30' Pumped Poured
 Cement Grout 0' to 100' Pumped Poured
 Concrete Grout _____ Pumped Poured
 ≥30% Bentonite Grout _____ Pumped Poured

Gravel Pack: Yes No 100' to 608' Pumped Poured
 Type: _____ BCJ 3/8" MINUS
 Bentonite Chips: Yes No _____ Pumped Poured
 Type: _____

Date started: 21-Mar 20 12
 Date completed: 24-Mar 20 12

7. Water Level
 Static water level: 177' feet below land surface
 Artesian Flow: NO G.P.M. 0 P.S.I.
 Water Temperature: COOL °F
 Quality: _____

8. WELL TEST DATA

TEST METHOD:	Bail	<input checked="" type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
CONSTANT			
Draw Down (Feet Below Static)	<u>153'</u>		
Time (Hours)	<u>11 HRS</u>		
	<u>38. 747355' N</u>		
	<u>119. 305908' W</u>		

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hydro Resources-West, Inc. Contractor
 Address 4975 W. Winnemucca Blvd. Contractor
Winnemucca NV, 89445

Nevada contractor's license number _____
 issued by the State Contractor's Board 56797
 Nevada driller's license number issued by the _____
 Division of Water Resources, the on-site driller # 2177

Signed Michelle Attothey
 By driller performing actual drilling on site or contractor

Date 4/17/2012

RECEIVED
 2012 APR 18 AM 10:24
 STATE ENGINEERS OFFICE

(Rev. 05-05)

ORIGINAL

USE ADDITIONAL SHEETS IF NECESSARY