

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 1150178
Permit No. 78185 + 78186
Basin 179

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65126

1. OWNER Robinson Nevada Mining **ORDER # 1198**
MAILING ADDRESS POB 382
NW NE Ruth, NV 89319 **R-675**
ADDRESS AT WELL LOCATION Robinson Nevada Mine Site
Subdivision Name: Mine Site County: White Pine
2. LOCATION NE 1/4 NW 1/4 Sec 15 T 16N N/S R 62 E
PERMIT/WAIVER No. 78186 Hole No. W-12-RR
Latitude UTM E 107358.9 NAD 27
Longitude N 101595.07 NAD 83/WGS 84
Issued by Water Resources Parcel No.

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Dump Material		0	100'	100'
Marble		100'	195	95
Porphyry, Marble		195	215	20
Porphyry, Gray		215	320	105
Porphyry, Marble and Skarn		320	345	25
Porphyry, Gray		345	670	325
Porphyry, Marble	X	670	690	20
Porphyry, Gray		690	1070	380
Hornfels	X	1070	1090	20
Porphyry, Gray		1090	1100	10

Waiver No. R-675
RECEIVED
2012 APR 30 PM 1:37
STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 1100 Feet Depth Cased 1003 Feet
HOLE DIAMETER (BIT SIZE)
From To
14 inches 0 Feet 165 Feet
9 7/8 inches 165 Feet 740 Feet
6 inches 740 Feet 1100 Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
10" 1/4 0 165
6" 1/4 0 740
4 Schedule 40 +2 1005
Perforations:
Type of perforation Factory
Size of perforation 8 Row .060 Slot
From 580 feet to 1000 feet
From _____ feet to _____ feet
Annular Seal: Yes No
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout 0 to 50' Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured
Gravel Pack: Yes No 50 to 1000 Pumped Poured
Type: 3/8" pea gravel
Bentonite Chips: Yes No _____ to _____ Pumped Poured
Type: _____

7. Water Level
Static water level: 456 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Air Lift	30	544	10

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. Contractor
Address 557 Ely Ave. Contractor
Ely, NV 89301
Nevada contractor's license number 14790
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed _____
By driller performing actual drilling on site or contractor
Date 10-April, 2012

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

39.257711°N
114.979418°W NA027