

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 115135  
Permit No. \_\_\_\_\_  
Basin 069

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67957

1. OWNER Robert Wade Field ADDRESS AT WELL LOCATION 6800 Dutch Flat Road Wmca NV  
MAILING ADDRESS P.O. Box 1103 Wmca NV 89446 Subdivision Name: Dutch Flat County: Humboldt

2. LOCATION NE 1/4 NE 1/4 Sec 19 T 38 N R 39 E Latitude UTM 447713  NAD 27  
PERMIT/WAIVER No. 1006-501-05 Longitude N 4556264  NAD 83/WGS 84

Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material               | Water Strata | From | To  | Thickness |
|------------------------|--------------|------|-----|-----------|
| Top Soil               |              | 0    | 5   | 5         |
| Yellow Clay            |              | 5    | 20  | 15        |
| Gravel Sand Clay       |              | 20   | 40  | 20        |
| Rocky Clay             |              | 40   | 60  | 20        |
| Sandy Clay             |              | 60   | 80  | 20        |
| Gravel Sand Clay       |              | 80   | 100 | 20        |
| Sandy Clay             |              | 100  | 120 | 20        |
| Sand Gravel Inter Clay |              | 120  | 150 | 30        |

9. WELL CONSTRUCTION  
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)  
From 10 5/8 Inches To 150 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 7/8</u>       |                     | <u>.122</u>             | <u>71</u>   | <u>150</u> |

Date started: 5-1-12 :20 12  
Date completed: 5-1-12 :20 12

Perforations:  
Type of perforation Torch Cut  
Size of perforation  
From 110 feet to 150 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 80% Bentonite Grout 5 to 50  Pumped  Poured

Gravel Pack:  Yes  No 90 to 150  Pumped  Poured  
Type: 3/8

Bentonite Chips:  Yes  No 50 to 90  Pumped  Poured  
Type: 3/8

7. Water Level  
Static water level: 74 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: Cold °F  
Quality: Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name LBJ DRILLING & PUMP COMPANY, INC. Contractor  
Address P.O. BOX 902 - Winnemucca, NV 89446 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0009605A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807  
Signed Joe Boggio  
By driller performing actual drilling on site or contractor  
Date \_\_\_\_\_

8. WELL TEST DATA

| TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | G.P.M.     | Draw Down (Feet Below Static) | Time (Hours) |
|---|------------|-------------------------------|--------------|
| <u>Rotary</u>   | <u>75+</u> | <u>UNS</u>                    | <u>2 hrs</u> |

(Rev. 06-08)

41.163335° N  
117.623235° W NAD27

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED  
2012 MAY -8 AM 10:41  
STATE ENGINEERS OFFICE