MW5

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115261
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36323

1. OWNER Dewey Strip Holdings LLC
MAILING ADDRESS 9440 W. Sahara Ave #240
Las Vega, Nv., 89117

ADDRESS AT WELL LOCATION 4207 S. Las Vegas Blvd., Las Vegas Nv.

2. LOCATION SW ¼ SW ¼ Sec 28 T 21S N/S R 61 E
PERMIT/WAIVER No. 162-28-401-001
Issued by Water Resources Parcel No.

Latitude 36 05' 22.29" N
Longitude 115 10' 19.22" W
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: County: Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other...

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphault		0	3"	#####
Type 2		3"	4.5	#####
Silty Sand Gravel		4.5	5	1
Calechie		5	6	1
Fine Silty Sand		6	7	1
Calechie		7	10.5	4
Fine Silty Sand		10.5	14.5	4
Calechie		14.5	17	3
Silty Clay		17	23	6
Calechie		23	24.5	2
Fine silty Sand		24.5	30	6

DCNR/DWR
RECEIVED
MAY 09 2012
LAS VEGAS OFFICE

Date started 4/18/2012 , 20
Date completed 4/18/2012 , 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
02		Schl 40	15	0

Perforations:
Type of perforation Machine Slot
Size of perforation 0.02
From 30 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 10
Placement Method: ☑ Pumped ☐ Poured
Gravel Packed: ☑ Yes ☐ No
From 30 feet to 13 feet

Seal Type:
☐ Neat Cement
☑ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling (Contractor)
Address 7150 Placid St. L.V., Nv. 89119 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 51266
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2399
Signed (By driller performing actual drilling on site or contractor)
Date 5/2/12

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY