STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115306
Permit No.
Basin 207

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68001

1. OWNER David Gibson
MAILING ADDRESS PO Box 203
Lund, NV 89317

ADDRESS AT WELL LOCATION Hwy 318 Gibson Rd
Subdivision Name: County: Nye

2. LOCATION NW¼ SW ¼ Sec 30 T 10 N/S R 61 E
PERMIT/WAIVER No. 013-681-12
Issued by Water Resources Parcel No.

Latitude 38° 41.858
Longitude 115° 10.226
UTM E 115065 9104 ☐ NAD 27
N 4284813 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Dirt		0	3	3
Clay, Sand		3	25	22
Clay, Sand, Gravel		25	80	55
70% Clay, 30% Very Coarse Sand		80	170	90
95% Blue Clay, Sand		170	190	20
65% Blue Clay; Sand		190	480	290
95% Brown Clay; Sand		480	625	145
40% Brown Clay, 1/4" gravel, sand		625	633	8
90% Brown Clay; Sand		633	720	87
1/8-1/4" Gravel		720	800	80

RECEIVED
2012 JUN 21 AM 11:53
STATE ENGINEERS OFFICE

Date started: May 17, 2012
Date completed: June 8, 2012

9. WELL CONSTRUCTION
Depth Drilled 800 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9 7/8	Inches	0	Feet	800	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	17.002	.250	+2	20
5.5		SCH 80	20	800

Perforations:
Type of perforation Mill
Size of perforation .020
From 700 feet to 800 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☒ Cement ~~Grout~~ Neat 650 to 700 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 650 ☐ Pumped ☒ Poured
Type: Pea 700 800 X
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 28 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Submersible	50		8 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Brothers Drilling
Contractor
Address PO Box 965
Contractor
Enterprise, UT 84725
Nevada contractor's license number issued by the State Contractor's Board 0068459
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2459
Signed Thever Gardner
By driller performing actual drilling on-site or contractor
Date June 19, 2012

(Rev. 05-06)
38.697700°N
115.169575°W
NAD 27

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)
(O) 627