

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 115310
 Permit No. _____
 Basin 069

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **68890**

1. OWNER **John Mentaberry & Jacqueline Ferraro** ADDRESS AT WELL LOCATION **Paradise Vasily**
 MAILING ADDRESS **PO Box 206 Paradise Valley, NV**

2. LOCATION NE 1/4 SE 1/4 Sec 110T41N/ R39E Subdivision Name: _____ County: **Humboldt**
 PERMIT/WAIVER NO. N/A Parcel No. 004-471-52 Latitude **41°26.812** UTM E NAD 27
 Longitude **117°33.710** N NAD 83/WGS 84

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand/Clay		0	2	2
Boulders		2	19	17
Clay		19	20	1
Boulders		20	35	15
Course sand & gravel		35	45	10
Cobles/Gravel		45	60	15
Clay		60	80	20
fine gravel/sand		80	100	20
cobles/clay		100	135	35
Clay		135	165	30
Course sand/gravel	X	165	200	35

9. WELL CONSTRUCTION
 Depth Drilled **200** Feet Depth Cased **200** Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 Inches **0** Feet **200** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	20
6.625	4.06	.316	20	200

Perforations:
 Type of perforation **Factory Cut Slots**
 Size of perforation **050**
 From **160** feet to **200** feet
 From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement 0 to 95 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured
 Gravel Pack: Yes No 100 to 200 Pumped Poured
 Type: _____
 Bentonite Chips: Yes No 95 to 100 Pumped Poured
 Type: _____

Date started: **May 4, 20 12**
 Date completed: **May 9, 20 12**

7. Water Level
 Static water level: **120** feet below land surface
 Artesian Flow: **N/A** G.P.M. **N/A** P.S.I
 Water Temperature: **Cool** °F
 Quality: **Good**

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	15		4
	41.446969°N	NAD27	
	117.560871°W		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Fred Anderson Drilling, Inc.** (CONTRACTOR)
 Address **10760 S. Grass Valley Road** (CONTRACTOR)
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board **021467**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2083**
 Signed *Fred Anderson Drilling Inc*
 By driller performing actual drilling on site contractor
 Date **June 19, 2012**

RECEIVED
 2012 JUN 21 AM 11:35
 STATE ENGINEERS OFFICE