STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115343
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68225

1. OWNER Robert & Sue Swearingen
MAILING ADDRESS 120 Sixth St
Winnemucca, Nv 89445

ADDRESS AT WELL LOCATION Corner of Kathy St & Sabin Dr
Winnemucca, Nv 89445
Subdivision Name: Tycanna County: Humboldt

2. LOCATION ~~NE~~ NW ¼ NE ¼ Sec 30 T 35N N/S R 38E E
PERMIT/WAIVER No. 010-643-17
Issued by Water Resources Parcel No.

Latitude 40.886256 N UTM E 437420 X [illegible]
Longitude 117.742807 E N 4526184

3. WORKED PERFORMED
X New Well Replace Recondition
Deepen Other

4. PROPOSED USE
X Domestic Irrigation Test
Municipal/Industrial Monitor Stock

5. WELL TYPE
Cable X Rotary RVC
Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy loam top soil		0	5	5
Med gravel clay & sand		5	10	5
Sand, small gravel & cobbles		10	80	70
Sand, med gravel & cobbles		80	220	140
Sand small gravel & clay		220	340	120
		340		
				340.00

RECEIVED
2012 JUN 18 PM 1:18
STATE ENGINEERS OFFICE

Date started: 5/8/~~2010~~ 2012
Date completed: 5/11/~~2010~~ 2012

9. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340

HOLE DIAMETER (BIT SIZE)

		From		To	
10 7/8	Inches	0	Feet	340	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	STEEL	.188	0	20
6.900	PVC	sdr21=.450 in	20	340

Perforations:
Type of perforation 6 inch pvc mill horrizontal slot screen
Size of perforation 1/32
From 300 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: Yes
Neat Cement to Pumped Poured
Cement Grout 0 to 150 Pumped X Poured
Concrete Grout to Pumped Poured
≥30% Bentonite Grout to Pumped Poured
Gravel Pack: X Yes No 100 to 340 Pumped X Poured
Type: 3/8 minus
Bentonite Chips: No to Pumped Poured
Type:

7. Water Level 260
Static water level: feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift x

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	25	50	4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Contractor High Desert Drilling LLC
Address Contractor 4225 E Mary Way
Winnemucca Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 62237
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140 & 2364
Signed [signature]
By driller performing actual drilling on site or contractor
Date 6-15-2012

(Rev. 06-06) USE ADDITIONAL SHEETS IF NECESSARY