

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115350
Permit No. _____
Basin φ 71

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66746

1. OWNER Russ Kenison ADDRESS AT WELL LOCATION well name: well # 3
MAILING ADDRESS 9505 s. buffalo rd. 9625 Buffalo Rd, Winnemucca, NV 89445
Winnemucca, Nv 89445 Subdivision Name _____ County Humboldt

2. LOCATION rw ¼ sw ¼ Sec 26 T 35n N/S R 36e E Latitude 40.87698n UTM E NAD 27
PERMIT/WAIVER No. 0 Parcel No. 005-601-03 Longitude 117.90881w N

3. WORKED PERFORMED Deepen Replace Recondition
4. PROPOSED USE Municipal/Industrial Irrigation Test Stock
5. WELL TYPE Cable Air Other RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy loam top soil		0	2	2
Med gravel clay & sand / cobbles		2	75	73
Grey clay w gravel, sand		75	90	15
Gravel & cobbles		90	220	130
Sand small gravel & clay		220	260	40
Hard cobbles		260	285	25
Gravel and sand w few cobbles		285	320	35
		320		

9. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320
HOLE DIAMETER (BIT SIZE)
11 Inches From 0 Feet To 320 Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	STEEL	.188	0	20
6.900	PVC	sdr21=.450 in	20	320

Perforations:
Type of perforation 6 inch pvc mill horizontal slot screen
Size of perforation 1/32
From 280 feet to 320 feet
From _____ feet to _____ feet

Annular Seal: Yes
Neat Cement _____ to _____ Pumped _____ Poured _____
Cement Grout 0 to 100 Pumped Poured _____
Concrete Grout _____ to _____ Pumped _____ Poured _____
≥30% Bentonite Grout _____ to _____ Pumped _____ Poured _____
Gravel Pack No 120 to 320 Pumped Poured _____
Type: 3/8 minus
Bentonite Chips: No 100 to 120 Pumped Poured _____
Type: 3/8 baroid

Date started: 11/4/2009
Date completed: 12/17/2009
2012
2012

7. Water Level
Static water level: 240 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: COLD °F
Quality: _____

8. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	x
AIR	20				4	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name High Desert Drilling LLC
Contractor _____
Address 4225 E Mary Way
Contractor _____
Winnemucca Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 62237
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140
Signed [Signature]
By driller performing actual drilling on site or contractor
Date _____

USE ADDITIONAL SHEETS IF NECESSARY
40.877076°N NA027
117.905842°W