STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115392
Permit No.
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62897

1. OWNER Don Tams (Don Tams)
MAILING ADDRESS Po Box 95 Winnemucca NV
ADDRESS AT WELL LOCATION N/A 17605 Rowdy Rd, Winnemucca, NV
Subdivision Name: N/A County: Humboldt

2. LOCATION SE ¼ NW ¼ Sec 29 T 36 N/S R 36 E
Latitude 40° 58' 10" N
Longitude 117° 57' 29" W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84
PERMIT/WAIVER No. N/A Issued by Water Resources
005-62421 Parcel No.

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Small Gravel		+1	150	150'
	X	+70		+150

Plugged by log 120237
Replaced by log 120236

Date started: 11/13, 20 11
Date completed: 11/15, 20 11

RECEIVED 2012 JUN 19 AM 10:49 STATE ENGINEERS OFFICE

7. Water Level
Static water level: 70 feet below land surface
Artesian Flow: 0 G.P.M. 0 P.S.I.
Water Temperature: Cool °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	8	8

9. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	+1 Feet	150 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
9		SDR 21	150	110
6		SDR 21	110	+1

Perforations:
Type of perforation Saw Cut Slots
Size of perforation 1/8" x 4" x 12" Spacing
From 150 feet to 90' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☒ Cement Grout	+1 to +56		☐ Pumped	☒ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No +56 to +150 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Tams (Contractor)
Address (Contractor)
Owner (owner)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
Signed (By driller performing actual drilling on-site or contractor)
Date 5/17/2012

USE ADDITIONAL SHEETS IF NECESSARY

40.969541°N NAD27
117.957084°W

(Rev. 05-06) (NSPO 3-08) (O) 627