

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36219

1. OWNER Charles & Mary Garrett ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2730 S. Winchester Ave. Pahrump NV 89048-5500 2730 S. Winchester Ave. Pahrump NV 89048-5500  
 2. LOCATION SE 1/4 SW 1/4 Sec. 29 T. 20 N. R. 53 E. Nye County  
 PERMIT NO. 40-242-29 Unit 5 Calvada Valley Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>N36°10'45.7" MAD 83</u>				
<u>W116°02'43.0"</u>				
<u>Existing 8" Steel Well</u>		<u>0</u>	<u>160</u>	<u>160</u>
<u>Clay</u>		<u>160</u>	<u>170</u>	<u>10</u>
<u>Caliche</u>	<u>WB</u>	<u>170</u>	<u>185</u>	<u>15</u>
<u>Clay</u>		<u>185</u>	<u>210</u>	<u>25</u>
<u>Caliche</u>	<u>WB</u>	<u>210</u>	<u>230</u>	<u>20</u>
<u>Clay</u>		<u>230</u>	<u>240</u>	<u>10</u>
<u>Caliche</u>	<u>WB</u>	<u>240</u>	<u>255</u>	<u>15</u>
<u>Clay</u>		<u>255</u>	<u>260</u>	<u>5</u>

8. WELL CONSTRUCTION  
 Depth Drilled 260 Feet Depth Cased 260 Feet  
 HOLE DIAMETER (BIT SIZE)  
 Existing \_\_\_\_\_ inches \_\_\_\_\_ feet  
7 7/8 inches 160 feet 260 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>160</u>
<u>4.5</u>	<u>2.37</u>	<u>.248</u>	<u>0</u>	<u>260</u>

Perforations:  
 Type perforation Screen  
 Size perforation .032  
 From 160 feet to 180 feet  
 From 200 feet to 220 feet  
 From 240 feet to 260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal Existing  
 Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 160 feet to 260 feet

9. WATER LEVEL  
 Static water level 91 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started September 12, 2012  
 Date completed September 12, 2012

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address 1220 Manse Rd. Pahrump NV 89048 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 47333  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 11126  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 9/13/12