STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115739
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36910

1. OWNER County of Clark
MAILING ADDRESS 500 S. Grand Central Pkwy
Las Vegas , Nv . 89155

ADDRESS AT WELL LOCATION Public Right-of-Way
(McLeod Dr. S. of E. Patrick Ln.) MW-11

2. LOCATION NW ¼ SE ¼ Sec 36 T 21S N/S R 61 E
PERMIT/WAIVER No. MO-2928 (Issued by Water Resources) 162-36-799-009 (Parcel No.)

Latitude 36.078385
Longitude -115.109724
UTM E
N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: County: Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... HAS

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	.4	0
Silty gravel w/ sand		.4	1.5	1
Silty sand	10.5	1.5	11	10
Sand w/silt and some gravel		11	18	7
Sandy lean clay w/some gravel		18	19	1
Silty sand w/some gravel		19	22	3
Sandy gravel w/silt		22	25	3
Sandy lean clay		25	27	2
Clayey sand w/gravel		27	28	1
Sandy lean clay		28	35	7

DCNR/DWR
RECEIVED
OCT 23 2012
LAS VEGAS OFFICE

Date started 18-Oct , 20 12
Date completed 18-Oct , 20 12

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7	Inches	0	Feet	35	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.0	PVC	SCH-40	0	35

Perforations:
Type of perforation Machine Slot
Size of perforation 0.02
From 35 feet to 10 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 8
Placement Method: ☐ Pumped ☑ Poured
Gravel Packed: ☑ Yes ☐ No
From 35 feet to 8 feet

Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 10.5 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services L L C. (Contractor)
Address 7150 Placid St. (Contractor)
Las Vegas Nv 89119
Nevada contractor's license number issued by the *State Contractor's Board* 51266
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2477-M
Signed (By driller performing actual drilling on site or contractor)
Date 19-Oct-12

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY

36.0784116
-115.1088939 NAD27