WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 115747
Permit No.
Basin 162

NOTICE OF INTENT NO. 36212

1. OWNER Mervin & Deanna Brown
MAILING ADDRESS 1711 Brown Band Ct. La Pine, OR. 97739
ADDRESS AT WELL LOCATION 1450 E. Deerskin St.

2. LOCATION SE ¼ NW ¼ Sec. 35 T. 20 N/S R. 53 E. Nye County
PERMIT NO. Issued by Water Resources | Parcel No. 42-692-21 | Subdivision Name Unit 3 Calvada Valley

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
N 36°10'14.1"				
W 115°59'16.6"				
Clay		0	5	5
Calichie		5	35	30
Clay		35	78	43
Calichie	WB	78	84	6
Clay		84	100	16
Calichie	WB	100	112	12
Clay		112	135	23
Calichie	WB	135	148	13
Clay		148	165	17
Calichie	WB	165	185	20
Clay		185	195	10
Calichie	WB	195	200	5

DCNR/DWR
RECEIVED
JUL 25 2012
LAS VEGAS OFFICE

Date started July 23, 2012, 20
Date completed July 23, 2012, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.63	.280	0	200

Perforations:
Type perforation Screen
Size perforation .032
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address 1220 Manse Rd. (Contractor)
Pahrump, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on site or contractor)
Date 7/12

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627