

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 115748  
Permit No. 80628  
Basin 209

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35762

1. OWNER Stewart Nevada Enterprises  
MAILING ADDRESS PO Box 777400  
Henderson, Nv. 89077

ADDRESS AT WELL LOCATION Midport 10  
U.S. 95 Hills, Nv.  
Subdivision Name: \_\_\_\_\_ County: Lincoln

2. LOCATION NE 1/4 NE 1/4 Sec 24 T 3 N/R 60 E  
PERMIT/WAIVER No. 80628 011-052-01  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude 37° 40.650 UTM E  NAD 83  
Longitude 115° 11.554 N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt, clay		0	82	82
clay		82	90	8
silt, sand		90	220	130
silt, sand, gravel		220	285	65
sand	X	285	410	125
sand, clay		410	435	25
sand, gravel, cobble	X	435	450	15
clay		450	478	28
silt, sand	X	478	700	222

Well 08A

DOWN DOWN RECEIVED

SEP 18 2012

LAS VEGAS OFFICE

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
700		700	

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
26"	0	700	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	62.4	.375	+2	700

Perforations:

Type of perforation Factory milled  
Size of perforation 3/16" x 2 1/2"  
From 255 feet to 700 feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 0 to 52  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 52 to 700  Pumped  Poured  
Type: 1/2" washed rock  
Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Date started: Feb 15 20 11  
Date completed: Mar 25 20 11

7. Water Level  
Static water level: 246.8 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: 54.2 °F  
Quality: Good

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)
<u>450</u>			<u>12 hrs</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Webber Drilling Contractor  
Address PO Box 40 Overton, Nv. Contractor

Nevada contractor's license number issued by the State Contractor's Board 0025887  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238

Signed Bryan Anzalone  
By driller performing actual drilling on-site or contractor  
Date Sept 10, 2012