

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115749
Permit No. 80627
Basin 209

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35761

1. OWNER Stewart Nevada Enterprises ADDRESS AT WELL LOCATION mile out 10
MAILING ADDRESS po Box 777400 Henderson Nv. 89077 Subdivision Name: U.S. 95 County: Hiko, Wv.
2. LOCATION SW 1/4 SE 1/4 Sec 24 T 3 N OR 60 E Latitude 37° 40' 28.1 UTM E 115° 11' 620 N 27
PERMIT/WAIVER No. 80627 011-050-01 Longitude 115° 11' 620 N 27 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test Monitor
 Municipal/Industrial Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay, silt		0	13	13
Clay, sand, cobble		13	60	47
Sand, clay		60	85	25
Sand, gravel, cobble		85	120	35
Clay, sand, gravel		120	195	75
Silt, sand, gravel		195	250	55
Clay		250	272	22
sand, gravel		272	340	68
Red Volcanics		340	700	360

Well 06A

SEP 13 2012

LAS VEGAS OFFICE

9. WELL CONSTRUCTION

Depth Drilled 700 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>26</u> Inches	<u>0</u> Feet	<u>700</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16</u>	<u>62.4</u>	<u>.375</u>	<u>+ 3</u>	<u>700</u>

Perforations:

Type of perforation Factory milled

Size of perforation 3/16 x 2 1/2

From 262 feet to 700 feet

From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured

Cement Grout to _____ Pumped Poured

Concrete Grout 0 to 55 Pumped Poured

≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 55 to 700 Pumped Poured

Type: 1/2" washed gravel

Bentonite Chips: Yes No _____ to _____ Pumped Poured

Type: _____

7. Water Level

Static water level: 234.4 feet below land surface

Artesian Flow: _____ G.P.M. _____ P.S.I.

Water Temperature: 52.6 °F

Quality: Good

8. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>600</u>		<u>8 hrs</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Webber Drilling Contractor

Address PO Box 40 Overton, Nv. 89040 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0025887

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238

Signed Bryan Arzabou By driller performing actual drilling on-site or contractor

Date Sept 10, 2012