

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **35482**

1. OWNER Troy J. Shipley ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2960 Jake St. Reno, NV. 89502-4922 12 Davis Meadow Trail  
 2. LOCATION NW 1/4 SW 1/4 Sec 29 T 1 N R 34 E Esmeralda County  
 PERMIT NO. 007-773-12 Parcel No. Lot 96 D / Fishlake Area Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<del>1000</del>				
<u>N37°49'20.896"</u>				
<u>W118°13'94.983"</u>				
<u>Loose Gravel &amp; Boulders</u>		<u>0</u>	<u>170</u>	<u>170</u>
<u>Loose Gravel &amp; Boulders</u>	<u>WB</u>	<u>170</u>	<u>175</u>	<u>5</u>
<u>Clay &amp; Gravel</u>		<u>175</u>	<u>210</u>	<u>35</u>
<u>Gravel &amp; Sand</u>	<u>WB</u>	<u>210</u>	<u>225</u>	<u>15</u>
<u>Gravel &amp; Boulders</u>	<u>WB</u>	<u>225</u>	<u>306</u>	<u>81</u>
<b>DCNR/DWR RECEIVED</b>				
<b>AUG 08 2012</b>				
<b>LAS VEGAS OFFICE</b>				

8. WELL CONSTRUCTION  
 Depth Drilled 306 Feet Depth Cased 306 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 100 Feet  
12 1/4 Inches 6 5/8 Inches  
 100 Feet 306 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>.188</u>	<u>16.94</u>	<u>0</u>	<u>100</u>
<u>6</u>	<u>10.78</u>	<u>.250</u>	<u>+1</u>	<u>306</u>

Perforations:  
 Type perforation Perforator  
 Size perforation 2 x .25  
 From 250 feet to 280 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 225 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started July 24, 2012  
 Date completed August 2, 2012

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address 1220 Marnie Rd. Pahrump, NV. 89048 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 47333  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1042  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 8/2/12