WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 115796
Permit No.
Basin 162

NOTICE OF INTENT NO. 36214

1. OWNER Reygers Family Trust
MAILING ADDRESS 1700 W Hickory St. Pahrump, NV. 89048
ADDRESS AT WELL LOCATION 1700 W. Hickory Street

2. LOCATION SE ¼ SW ¼ Sec. 29 T. 20 N/S R. 53 E. Nye County
PERMIT NO. Issued by Water Resources | Parcel No. 40-381-26 | Subdivision Name Unit 5 Calvada Valley

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
N36°10'45.11" W116°02'37.68"	WGS 84			
Existing 140' 8" Steel Well				140
Clay		140	155	15
Caliche	WB	155	168	13
Clay		168	195	27
Caliche	WB	195	215	20
Clay		215	238	23
Caliche	WB	238	250	12
Clay		250	260	10

DCNR/DWR
RECEIVED
JUL 20 2012
LAS VEGAS OFFICE

Date started July 16, 2012
Date completed July 16, 2012

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
EXISTING Inches	0 Feet	140 Feet
7 7/8 Inches	140 Feet	260 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	.188	0	140
4.5	2.37	.248	140	260

Perforations:
Type perforation Screen
Size perforation .032
From 160 feet to 180 feet
From 200 feet to 220 feet
From 240 feet to 260 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal Existing
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140 feet to 260 feet

9. WATER LEVEL
Static water level 86 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address 1220 Manse Rd. Pahrump, NV. 89048 Contractor
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed [signature] By driller performing actual drilling on site or contractor
Date 7/17/12

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

36.179236 (O)-627
-116.0429399 - NAD27