STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115925
Permit No.
Basin 137B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67844

1. OWNER Round Mountain Gold Corp. HD-12-2-F
MAILING ADDRESS PO Box 480
Round Mountain, NV 89045

ADDRESS AT WELL LOCATION Round Mountain Mine
Round Mountain, NV
Subdivision Name: County: Nye

2. LOCATION SE¼NE¼ Sec30T10N/ R44E
PERMIT/WAIVER NO. M/O - 1796 (Issued by Water Resources) Parcel. No.

Latitude
Longitude
UTM E 493310 ☒ NAD 27
N 4283121 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other Horizontal Drain

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Non welded volcanic tuff				
Type 3 (gray rock)		0	320	320
Intusive granite				
Type 8 (lt. gray rock)		320	740	420
Hole caves in @680'				

Date started: February 23, 20 12
Date completed: February 24, 20 12

9. WELL CONSTRUCTION
Depth Drilled 740 Feet Depth Cased 670 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7 Inches	0 Feet	20 Feet
5.75 Inches	20 Feet	740 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.95	.188	+10	20
1.5	.69	.145	+10	670

Perforations:
Type of perforation Slotted
Size of perforation 0.02
From 10 feet to 670 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

RECEIVED 2012 MAR 14 AM 10:40 NEVADA ENGINEER'S OFFICE

7. Water Level
Static water level: Hlt water @ 510 feet below land surface
Artesian Flow: 4 G.P.M. N/A P.S.I
Water Temperature: warm °F
Quality: N/A

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A	N/A	
	NAD27	
	38.678552°N	
	117.076920°W	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Drilling Services (CONTRACTOR)
Address 2745 California Avenue (CONTRACTOR)
Salt Lake City, UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2329
Signed [signature] By driller performing actual drilling on site or contractor
Date March 1, 2012

Forms Provided by Forms-On-A-Disk • (214) 340-9429 • FormsOnADisk.com