STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115960
Permit No.
Basin No. Ø56

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69264 ✓
WELL NAME (If applicable):

1. OWNER/CLIENT NAME James Gallager + Ida
MAILING ADDRESS HC 61 Box 246
Eureka, NV 89310

DETAILED ADDRESS AT WELL LOCATION HC 61 Box 246
Eureka, NV 89310
Subdivision Name: County: Eureka

2. PLS LOCATION SW ¼ SE ¼ 11 Sec 20N N/S 43 E
PERMIT/WAIVER NO. Issued by Water Resources 005-350-13 Current Parcel No.

Latitude 39.60612 N UTM E ☐ NAD 27
Longitude 117.10707 W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# Unknown
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Gravel w/s Rock			300	400	100
x					

RECEIVED 2012 OCT 30 AM 10:15 STATE ENGINEERS OFFICE

Date started: 22-Sep, 20 12
Date completed: 22-Sep, 20 12

9. WELL CONSTRUCTION
Depth Drilled: 400 Feet Depth Cased: 400 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	280	Feet	400	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5.563	10.79	.188	400	280

PERFORATIONS:
Type of perforation: Mill Cut
Size of perforation: .032
From 330 Feet To 400 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☐ Sanitary Seal to
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

7. WATER QUALITIES
Static water level: 281 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality: Unknown

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
39.	606196°N	NAD27
117.	106144°W	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc
Contractor
Address P.O. Box 1265 Fallon, NV 89407
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 29064
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2307

Signed: [signature]
By driller performing actual drilling on site or contractor
Date: 10/21/2012

(Rev. 06-12)

USE ADDITIONAL SHEETS IF NECESSARY