STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115987
Permit No.
Basin 106

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69138

1. OWNER Great Escape Partnership
MAILING ADDRESS 787 Panther Drive
Reno, NV 89506

ADDRESS AT WELL LOCATION 2035 Comstock Rd
Gardnerville, NV 89410
Subdivision Name: County: Douglas

2. LOCATION NE ¼ NW ¼ Sec 32 T 10 N/ R 22 E
PERMIT/WAIVER NO. 1022-32-110-038
Issued by Water Resources Parcel. No.

Latitude 38.690795 UTM E ☐ NAD 27
Longitude -119.544759 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this day we installed a 4" ID liner into the well. We installed it to block the roots from growing into the well. The liner starts at 10' and goes to bottom at 80'.				
* original log UNKNOWN				

Date started: 11/21, 20 12
Date completed: 11/21, 20 12

7. Water Level
Static water level: 42 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: cool °F
Quality: not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	3	3
38.690887 °N	NAD27	
119.543757 °W		

9. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		.188	10	80

Perforations:
Type of perforation Factory Cut
Size of perforation 3/32 x 2.5"
From 50 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (CONTRACTOR)
Address 1600 Mt. Rose Hwy (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2326
Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor
Date 11/26/2012

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com