

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115997
Permit No. _____
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Dennis Baller + Kathie ADDRESS AT WELL LOCATION 5245 Trousdale Cir. Winnemucca NV. 89445
MAILING ADDRESS 4144 Two Rock Rd. SE Winnemucca NV. 89445 Subdivision Name: T. Quarter Circle Div. County: Humboldt
2. LOCATION NE 1/4 NE 1/4 Sec 2 T 35 S R 37 E Latitude N 40° 56' 37.8" UTM E NAD 27
PERMIT/WAIVER No. 013-101-10 Longitude W 117° 46' 52.1" N NAD 83/WGS 84

3. WORKED PERFORMED New Well Replace Recondition Deepen Other
4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE Cable Rotary RVC Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand	NO	0	7	7
Clay Sand Gravel	NO	7	40	33
Coarse Gravel	YES	40	100	60
Gravel Sand	YES	100	160	60
Gravel Clay Sand	YES	160	200	40

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet
HOLE DIAMETER (BIT SIZE)
10 7/8 Inches From 0 Feet To 200 Feet
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>Steel</u>	<u>.188</u>	<u>0</u>	<u>20</u>
<u>6 3/8</u>	<u>PVC</u>	<u>Sched 40</u>	<u>20</u>	<u>200</u>

RECEIVED
2012 DEC 3 AM 11:30
STATE ENGINEERS OFFICE

Perforations:
Type of perforation slot
Size of perforation .20
From 160 feet to 200 feet
Annular Seal: Yes No
 Neat Cement 0 to 50 Pumped Poured
 Cement Grout Pumped Poured
 Concrete Grout Pumped Poured
 ≥30% Bentonite Grout Pumped Poured
Gravel Pack: Yes No 50 to 200 Pumped Poured
Type: _____
Bentonite Chips: Yes No 50 to 52 Pumped Poured
Type: 3/8"

7. Water Level
Static water level: 34 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40+</u>	<u>NA</u>	<u>3</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. Contractor
Address 5140 Jungb Rd. Winnemucca NV. 89445 Contractor
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed [Signature]
By driller performing actual drilling on-site or contractor
Date 11-21-12