

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY

Log No. 116110
 Permit No. _____
 Basin 104

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 60187

1. OWNER City of Carson City ADDRESS AT WELL LOCATION W 3rd St between Scaram+Scumy Carson City, NV
 MAILING ADDRESS 13505 Butth Way Carson City, NV 89401
 2. LOCATION NW 1/4 SW 1/4 Sec. 17 T. 15 N. S. R. 20 E. Carson City County Carson City
 PERMIT NO. _____ Parcel No. _____ Subdivision Name 39° 09' 45.45" N 119° 46' 02.11" W
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thickness
		18	0	31

Well was in good shape. Put drill rod down the casing & knocked plug out pump grouted from bottom to top.

RECEIVED
 2013 FEB -4 AM 11:09
 STATE ENGINEERS OFFICE

Plugs well log 111626

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased 31 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>				

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 31
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 18 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 1/22 2013
 Date completed 1/22 2013

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>W/A</u>	<u>NAD 27</u>	<u>39.162715° N</u> <u>119.766238° W</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andresen Drilling Contractor
 Address 1135 Belford rd. Reno, NV 89509 Contractor
 Nevada contractor's license number 34525 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1028
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 1/30/13