STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116149
Permit No.
Basin 102

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36228

1. OWNER ARTHUR ADAMS
MAILING ADDRESS 4300 E COMANCHE DR
PAHRUMP NV 89061

ADDRESS AT WELL LOCATION 4260 E COMANCHE DR
Subdivision Name: GREEN SADDLE RANCH County: NYE

2. LOCATION NE ¼ SW ¼ Sec 20 T 21S N/S R 54 E
PERMIT/WAIVER No. 45-311-25 (Issued by Water Resources) Parcel No.

Latitude N36°06'32.1" Longitude W115°56'07.6"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	15	15
CALICHIE		15	26	11
CLAY		26	75	49
CALICHIE	WB	75	88	13
CLAY		88	120	32
CALICHIE	WB	120	125	5
CLAY		125	155	30
CALICHIE	WB	155	175	20
CLAY		175	180	5
CALICHIE	WB	180	195	15
CLAY		195	200	5

DCNR/DWR RECEIVED DEC 27 2012 LAS VEGAS OFFICE

Date started 3-Dec , 20 12
Date completed 4-Dec , 20 12

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.280	0	200

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 50 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 200 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level 74 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address 1220 MANSE RD (Contractor)
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on site or contractor)
Date 17-Dec-12

(Rev. 05/06)

USE ADDITIONAL SHEETS IF NECESSARY

36.108953
-115.934589 -NAD27