STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116186
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35629

1. OWNER Ewing Rex Cir, Ewing Bros Inc, Ewing Bros Auto Body
MAILING ADDRESS 1200 N. A St., Las Vegas, NV 89106
ADDRESS AT WELL LOCATION 1300 A St.
Subdivision Name. County: Clark

2. LOCATION NW¼ NE ¼ Sec 27 T 20 N/S R 61 E
PERMIT/WAIVER No. 134-27-501-007
Issued by Water Resources Parcel No.
Latitude 36.18507 UTM E ☐ NAD 27
Longitude 115.14173 N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	3	3
Caliche, lt brown		3	4	1
Clayey sand w/gravel		4	7	3
Silty clay w/gravel		7	11	4
Silty sand		11	14	3
Sandy clay		14	18	4
Silty clay w/gravel		18	25	7
Sandy clay, brown, very moist to wet	26	25	34.5	9.5

Date started: 9/6 , 20 12
Date completed: 9/6 , 20 12

7. Water Level
Static water level: 26 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR
RECEIVED
NOV 06 2012

9. WELL CONSTRUCTION
Depth Drilled 34.5 Feet Depth Cased 34.5 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	34.5	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	Sch 40	0	32.5

Perforations:
Type of perforation Factory
Size of perforation .020
From 32.5 feet to 34.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 25' ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 32 to 34.5 ☐ Pumped ☒ Poured
Type: #16
Bentonite Chips: ☒ Yes ☐ No 25 to 32 ☐ Pumped ☒ Poured
Type: Holeplug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc. Contractor
Address PO Box 96565 Contractor
Las Vegas, NV 89193-6565
Nevada contractor's license number issued by the State Contractor's Board 0054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 10-1869
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 10/15/12

RECEIVED
OCT 23 2012
FLAMINGO

USE ADDITIONAL SHEETS IF NECESSARY

36.185100 - NAD 27
- 115.140895

LAS VEGAS OFFICE