STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116192
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36815

1. OWNER Ewing Rex C Jr, Ewing Bros Inc, Auto Body (Ewing Bros)
MAILING ADDRESS 1200 N. ASH, Las Vegas, NV 89106
ADDRESS AT WELL LOCATION 1300 A. St.
Subdivision Name:
County: Clark

2. LOCATION NW ¼ NE ¼ Sec 27 T 20 N/S R 61 E
PERMIT/WAIVER No. 139-27-501-007 (Issued by Water Resources) Parcel No.
Latitude 36.18513
Longitude 115.14173
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	4	4ft
Clayey sand w/gravel, brown		4	7	3ft
Silty clay, lt Brown		7	9	2ft
Caliche, brown, very hard		9	10	1ft
Silty sand, lt Brown		10	14	4ft
Sandy Clay, lt Brown		14	18	4ft
Silty Clay, lt Brown		18	25	7ft
Sandy clay, brown, very moist		25	27	2ft

Date started: 9/5 20 12
Date completed: 9/5 20 12

7. Water Level
Static water level: feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DONE/DWR RECEIVED NOV 06 2012

9. WELL CONSTRUCTION
Depth Drilled 27 Feet Depth Cased 27 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	27 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	PVC	Sch 40	0	22

Perforations:
Type of perforation Factory
Size of perforation .020
From 22 feet to 27 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 15 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 21.5 to 27 ☐ Pumped ☒ Poured
Type #12
Bentonite Chips: ☒ Yes ☐ No 15 to 21.5 ☐ Pumped ☒ Poured
Type: Hole plug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
RECEIVED OCT 23 2012 FLAMINGO
Name Elite Drilling Inc. (Contractor)
Address PO Box 96565 (Contractor)
Las Vegas, NV 89193-6565
Nevada contractor's license number issued by the State Contractor's Board 0054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed (By driller performing actual drilling on-site or contractor)
Date 10/15/12

USE ADDITIONAL SHEETS IF NECESSARY

LAS VEGAS OFFICE

36.185160 - NAD 27
-115.140895

(NSPO 3-08) (O) 627