

ORIGINAL

Page 1 of 2

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116386
Permit No. 29257, 29258
Basin 069

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68524

1. OWNER WINNEMUCCA FARMS INC.
MAILING ADDRESS ONE POTATO RD. WINNEMUCCA
NEVADA, 89445

ADDRESS AT WELL LOCATION WELL # 4
Subdivision Name County: Humboldt

2. LOCATION NE 1/4 NE 1/4 Sec 30 T 39N N/S R 39 E
PERMIT/WAIVER No. 29257/29258

Latitude 41* 13.987 N UTM E NAD 27
Longitude 117* 37.232 W N NAD 83/WGS 84

3. WORKED PERFORMED
New Well Replace Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal/Industrial Monitor Stock

5. WELL TYPE
Cable Rotary RVC
Air Other

LITHOLOGIC LOG table with columns: Material, Water Strata, From, To, Thickness. Includes handwritten notes: 'RECEIVED', 'Replaces original well log # 15367, which was plugged under well # 68525 log 111452'.

WELL CONSTRUCTION table with columns: Depth Drilled, Feet, Depth Cased, Feet. Includes HOLE DIAMETER (BIT SIZE) section.

CASING SCHEDULE table with columns: Size O.D. (Inches), Weight/Ft. (Pounds), Wall Thickness (Inches), From (Feet), To (Feet).

PERFORATIONS table with columns: Type of perforation, Size of perforation, MILL SLOT (0.090").

Annular Seal: Yes No
Neat Cement 0' to 50'
Cement Grout
Concrete Grout
230% Bentonite Grout

Gravel Pack: Yes No
Type: HUNEWILL 1/4" X 1/8"
Bentonite Chips: Yes No

7. Water Level
Static water level: 61' feet below land surface
Artesian Flow: NO G.P.M. 0 P.S.I.
Water Temperature: COOL °F
Quality:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: Hydro Resources-West, Inc.
Address: 4975 W. Winnemucca Blvd.
Winnemucca NV, 89445
Nevada contractor's license number: 56797
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: # 2158
Signed: Michelle Strother
Date:

8. WELL TEST DATA table with columns: TEST METHOD (Bailer, Pump, Air Lift), G.P.M., Draw Down (Feet Below Static), Time (Hours). Includes handwritten test results for CONSTANT, 41, and 117.

