STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116387
Permit No.
Basin No. 071

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63223
WELL NAME (If applicable):

1. OWNER/CLIENT NAME CMH Homes, Inc/Rawhide Estates, LLC
MAILING ADDRESS 10020 Hwy 50 E
Carson City, NV 89706

DETAILED ADDRESS AT WELL LOCATION 4875 Stirrup St.
Winnemucca NV. 89445
Subdivision Name: Rawhide Estates County: Humboldt

2. PLS LOCATION NE ¼ NE ¼ 31 Sec 35 N/S 38 E
PERMIT/WAIVER NO. 010-623-03
Issued by Water Resources Current Parcel No.

Latitude N 40'52.224 UTM E
Longitude W 117' 44.404 UTM N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
clay and cobbles			0	100	100
clay and gravel			100	320	220

Date started: 27-Feb, 20 13
Date completed: 28-Feb, 20 13

9. WELL CONSTRUCTION
Depth Drilled: 320 Feet Depth Cased: 320 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	320	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	320

PERFORATIONS:
Type of perforation: Mill slot
Size of perforation: 0.09
From 260 Feet To 320 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☐ Sanitary Seal		to		
☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 100	☒ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]	100	to 320	☐ Pumped	☒ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 205 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality: good

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20		3 hr

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Stonehouse Drilling (Contractor)
Address 7801 Lakeside Dr. Reno NV. 89511 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0069994
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1713
Signed: (By driller performing actual drilling on site or contractor) office
Date: 3/3/13

(Rev. 08-12) USE ADDITIONAL SHEETS IF NECESSARY

40.870496°N
117.739104°W
NAD27

RECEIVED 2013 MAR -5 AM 10:30 STATE ENGINEER'S OFFICE