STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116394
Permit No.
Basin 103

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69831

1. OWNER SCOTT LARKIN
MAILING ADDRESS 1260 S. DEER RUN RD
CARSON CITY, NV 89706

ADDRESS AT WELL LOCATION 1260 S. DEER RUN RD.
CARSON CITY, NV 89706
Subdivision Name: County: Carson City

2. LOCATION NW ¼ NE ¼ Sec 23 T 15N N/S R 20 E
PERMIT/WAIVER No. 010-082-14
Issued by Water Resources Parcel No.

Latitude 39.15552*N
Longitude 119.701231*W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 6 5/8 WELL		0	140	140
COURSE DG SANDS		140	175	35
BROWN CLAY		175	200	25
OBSIDIAN GRAVELS	XXX	200	220	20
LOSS CIRCULATION				
Original log being deepened - unknown				

Date started: 12-Feb, 20 13
Date completed: 14-Feb, 20 13

9. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	140	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 1/2	3.25	.216	100	120

Perforations:
Type of perforation FACTORY SLOT
Size of perforation .032
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 135 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 93 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	30	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 02/14/2013

(Rev. 05-06) USE ADDITIONAL SHEETS IF NECESSARY

39.155610°N
119.700220°W NAD27

RECEIVED 2013 FEB 19 PM 1:33 STATE ENGINEER'S OFFICE