

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 116396  
Permit No. \_\_\_\_\_  
Basin 069

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66764

1. OWNER Pauline Lambert  
MAILING ADDRESS 4085 Lambert Dr. Winnemucca NV 89445

ADDRESS AT WELL LOCATION Georgia Circle Winnemucca NV  
Subdivision Name: Lambert County: Humboldt

2. LOCATION NE 1/4 SW 1/4 Sec 10 T 37N S R 38 E  
PERMIT/WAIVER No. 006-012-50  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude N41° 03' 755 UTM E  NAD 27  
Longitude W117° 41' 408 N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sand</u>	<u>NO</u>	<u>0</u>	<u>10</u>	<u>10</u>
<u>Dark Clay</u>	<u>NO</u>	<u>10</u>	<u>45</u>	<u>35</u>
<u>Clay</u>	<u>NO</u>	<u>45</u>	<u>55</u>	<u>10</u>
<u>Gravel Sand</u>	<u>YES</u>	<u>55</u>	<u>100</u>	<u>45</u>

9. WELL CONSTRUCTION

Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>10 7/8</u>	<u>0</u>	<u>100</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>19.8</u>	<u>Steel</u>	<u>0</u>	<u>20</u>
<u>6 7/8</u>	<u>schedule</u>	<u>40 PVC</u>	<u>20</u>	<u>100</u>

Date started: 5-5, 20 11  
Date completed: 5-10, 20 11

Perforations:

Type of perforation SLOT  
Size of perforation .25

From 80 feet to 100 feet

Annular Seal:  Yes  No

Neat Cement 0 to 50  Pumped  Poured  
 Cement Grout to  Pumped  Poured  
 Concrete Grout to  Pumped  Poured  
 ≥30% Bentonite Grout to  Pumped  Poured

Gravel Pack:  Yes  No 50 to 100  Pumped  Poured  
Type: 1/8" pea gravel

Bentonite Chips:  Yes  No to  Pumped  Poured

7. Water Level  
Static water level: 51 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: Cold °F  
Quality: Clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Alternative Drilling Contractor  
Address 197 Western Blvd Contractor  
Sparks Nevada NV

Nevada contractor's license number \_\_\_\_\_  
Issued by the State Contractor's Board 00073955  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730

Signed Herald Moritz  
By driller performing actual drilling on-site or contractor  
Date 5-11-11

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>0</u>	<u>3 1/2</u>